

NTPC LTD

CC-OS

EOC NOIDA

Sub: Qualifying Requirement for Vendor Enlistment for supply of Ceiling Fans

A)	MEG DETAILS		
	1.0	MEG NO.	35MEC-01
	2.0	MEG DESCRIPTION	Ceiling Fans
	3.0	RESPONSIBILITY CENTRE	NR
B)	Technical Criteria of QR: 1. Vendor should be a Ceiling Fan manufacturer 2. Vendor should have successfully executed orders for supply of BEE 5 Star Rating Ceiling Fans of minimum sweep of 1200mm during last Five years from the date of application. 3. Vendor should have valid BIS Licence for Ceiling Fans.		
C)	Other Documents to be submitted: In addition to the documents required in support of meeting technical requirements as stated above, following documents are required to be submitted by the Applicants applying for enlistment:- 1. Three POs of the highest executed values of similar work during previous five years from the date of application. Copy of Invoice / Completion certificate from the concerned buyer/s in support of successful execution of supply against the POs to be submitted. 2. Audited balance sheet including Profit & Loss statement for the previous three completed financial years reckoned from the date of application. In case the audited documents are not ready / available, then certified copy by a registered practicing Chartered accountant may be submitted. 3. Latest annual report OR NSIC / SSI / MSME registration certificate / BIS license / ISO certificate / Certificate of registration from the concerned excise department / any other statutory document as a proof of being manufacturer of the required material. 4. Any other documents in addition to the above which the applicant wants to submit.		
D)	NOTE-1	Similar works means: Supply of Ceiling Fans as per relevant IS.	
	NOTE-2	The executed value means Basic value of quantity of similar works executed/supplied against the reference PO(also applicable to partly executed POs as on date of application).Where PO value is composite(i.e. including Taxes etc.),the applicant to give item-wise break-up of Composite PO value mentioning Basic Value, Taxes etc.	

NTPC LTD
CC-OS
EOC NOIDA

Sub: Technical Specifications for Vendor Enlistment for supply of Ceiling Fans

A)	MEG DETAILS		
	1.0	MEG NO.	35MEC-01
	2.0	MEG DESCRIPTION	Ceiling Fans
	3.0	RESPONSIBILITY CENTRE	NR
B)	Technical Specifications: 1. Electric Ceiling Fans shall be Capacitor Type, with double ball bearing complete with capacitor, 300 mm down rods, canopies, minimum three number blades made of aluminium alloy, with suitable electronic type regulator, suitable for operation on single phase, AC 230 - 250 Volt, 50Hz supply and shall conform to relevant IS with latest amendments. 2. The Electronic Regulators step type shall conform to the requirements of relevant IS with latest amendments. 3. Ceiling Fans should be ISI marked and BEE 5 Star marked. Add on Items: Down Rods Shall be suitable for 1200mm and 1400mm sweep Ceiling Fans. These down rods will be in addition to the down rod of 300 mm length being supplied with the Electric Ceiling Fan.		