

NTPC LTD
CC-OS
EOC NOIDA

Sub:Qualifying Requirement For Vendor Enlistment For Supply Of “Metallic Expansion Joints”

A)	MEG DETAILS	
1.0	MEG NO.	46MEC-14
2.0	MEG DESCRIPTION	Metallic Expansion Joints
3.0	RESPONSBLITY CENTRE	WR-II
B)	Technical Criteria of QR: The applicant should be (1) A manufacturer of Metallic Expansion Bellows /Joints as per drawing & specification. (2) The applicant should have supplied such items during last five years as on the date of application to thermal power stations	
C)	Other Documents is to be Submitted: In addition to the documents required in support of meeting technical requirements as stated above, following documents are required to be submitted by the applicants applying for enlistment:- 1. Three POs of the highest executed values of similar work during previous five years from the date of application. Copy of Invoice / Completion certificate from the concerned buyer/s in support of successful execution of supply against the POs is to be submitted. 2. Audited balance sheet including Profit & Loss statement for the previous three completed financial years reckoned from the date of application. In case the audited documents are not ready / available, then certified copy by a registered practicing Chartered accountant may be submitted. 3. Latest annual report OR NSIC / SSI / MSME registration certificate / BIS license / ISO certificate / Certificate of registration from the concerned excise department / any other statutory document as a proof of being manufacturer of the required material. 4. Any other documents in addition to the above which the applicant wants to submit.	

D)	Note-1	Similar work means Supply of Metallic Expansion Bellows /Joints as per drawing to thermal power station
	Note-2	The executed value means basic value of quantity of similar works executed/supplied against the reference PO(also applicable to partly executed POs as on date of application).Case(s) where PO value is composite(i.e. including taxes etc.),the applicant has to give item-wise break-up of composite PO value mentioning basic value,taxes etc.

NTPC LTD
CC-OS
EOC NOIDA

Sub:Technical Specification For Vendor Enlistment For Supply Of “Metallic Expansion Joints”

A)	MEG DETAILS		
1.0	MEG NO.	46MEC-14	
2.0	MEG DESCRIPTION	Metallic Expansion Joints	
3.0	RESPONSIBILITY CENTRE	WR-II	
B)	Technical Specifications: These joints are used in the Air / Flue gas ducting to take care of expansion requirements. The size of the expansion joints shall be as per drawings attached with enquiry. Material : Cold reduced low carbon steel as per IS 513 (Deep Drawn).		