

**NTPC LTD****CC-OS****EOC NOIDA****Sub: Qualifying Requirement for Vendor Enlistment for supply of Signalling Cables**

A)	MEG DETAILS		
	1.0	MEG NO.	75MEC-03(A)
	2.0	MEG DESCRIPTION	Signalling Cables
	3.0	RESPONSIBILITY CENTRE	WR-I
B)	<b>Technical Criteria of QR:</b> 1. The Applicant should be manufacturer of upto 1.1 kV Grade Flexible Signalling Cable. 2. The applicant should have supplied as per IRS-S_63/2007		
C)	<b>Other Documents to be submitted:</b> In addition to the documents required in support of meeting technical requirements as stated above, following documents are required to be submitted by the Applicants applying for enlistment:- 1. Three POs of the highest executed values of similar work during previous five years from the date of application. Copy of Invoice / Completion certificate from the concerned buyer/s in support of successful execution of supply against the POs to be submitted. 2. Audited balance sheet including Profit & Loss statement for the previous three completed financial years reckoned from the date of application. In case the audited documents are not ready / available, then certified copy by a registered practicing Chartered accountant may be submitted. 3. Latest annual report OR NSIC / SSI / MSME registration certificate / BIS license / ISO certificate / Certificate of registration from the concerned excise department / any other statutory document as a proof of being manufacturer of the required material. 4. Any other documents in addition to the above which the applicant wants to submit.		
D)	NOTE-1	Similar works means: Supply of upto 1.1kV Grade Signal / Control Cable.	
	NOTE-2	The executed value means Basic value of quantity of similar works executed/supplied against the reference PO(also applicable to partly executed POs as on date of application).Where PO value is composite(i.e. including Taxes etc.),the applicant to give item-wise break-up of Composite PO value mentioning Basic Value, Taxes etc.	

**NTPC LTD**  
**CC-OS**  
**EOC NOIDA**

**Sub: Technical Specifications for Vendor Enlistment for supply of Signalling Cables**

A)	MEG DETAILS		
	1.0	MEG NO.	75MEC-03(A)
	2.0	MEG DESCRIPTION	Signalling Cables
	3.0	RESPONSIBILITY CENTRE	WR-I
B)	<b>Technical Specifications:</b> PVC insulated with High Conductive Annealed Copper Conductor, armoured confirming to Spec .No. IRS-S-63/2007 with latest amendment.		