

**NTPC LTD**

**CC-OS**

**EOC NOIDA**

**Sub: Qualifying Requirement for Vendor Enlistment for supply of Signalling Cables (Jelly Filled)**

A)	MEG DETAILS		
	1.0	MEG NO.	75MEC-03(B)
	2.0	MEG DESCRIPTION	Signalling Cables (Jelly Filled)
	3.0	RESPONSIBILITY CENTRE	WR-I
B)	<p><b>Technical Criteria of QR:</b></p> <p>1. The Applicant should be manufacturer of Signalling Cable upto 1.1 KV Grade Jelly Filled Flexible Cable.</p> <p>2. The applicant should have supplied as per IRS-S_63/2007</p>		
C)	<p><b>Other Documents to be submitted:</b> In addition to the documents required in support of meeting technical requirements as stated above, following documents are required to be submitted by the Applicants applying for enlistment:-</p> <p>1. Three POs of the highest executed values of similar work during previous five years from the date of application. Copy of Invoice / Completion certificate from the concerned buyer/s in support of successful execution of supply against the POs to be submitted.</p> <p>2. Audited balance sheet including Profit &amp; Loss statement for the previous three completed financial years reckoned from the date of application. In case the audited documents are not ready / available, then certified copy by a registered practicing Chartered accountant may be submitted.</p> <p>3. Latest annual report OR NSIC / SSI / MSME registration certificate / BIS license / ISO certificate / Certificate of registration from the concerned excise department / any other statutory document as a proof of being manufacturer of the required material.</p> <p>4. Any other documents in addition to the above which the applicant wants to submit.</p>		
D)	NOTE-1	Similar works means: Supply of up to 1.1KV Grade Jelly Filled Signal / Control Cable.	
	NOTE-2	The executed value means Basic value of quantity of similar works executed/supplied against the reference PO(also applicable to partly executed POs as on date of application).Where PO value is composite(i.e. including Taxes etc.),the applicant to give item-wise break-up of Composite PO value mentioning Basic Value, Taxes etc.	

**NTPC LTD**  
**CC-OS**  
**EOC NOIDA**

**Sub: Technical Specifications for Vendor Enlistment for supply of Signalling Cables (Jelly Filled)**

A)	MEG DETAILS		
	1.0	MEG NO.	75MEC-03(B)
	2.0	MEG DESCRIPTION	Signalling Cables
	3.0	RESPONSIBILITY CENTRE	WR-I
B)	<b>Technical Specifications:</b> PVC insulated with High Conductive Annealed Copper Conductor, armoured confirming to Spec. No. IRS-S-63/2007 with latest amendment.		