

NTPC LTD

CC-OS

EOC NOIDA

Sub: Qualifying Requirement for Vendor Enlistment for supply of LT Motor (Above 100 KW)

A)	MEG DETAILS		
	1.0	MEG NO.	86MEC-01(C)
	2.0	MEG DESCRIPTION	LT Motor (Above 100 KW)
	3.0	RESPONSIBILITY CENTRE	WR-I
B)	<p>Technical Criteria of QR:</p> <p>1. The Applicant should be a manufacturer of 415 V Squirrel Cage Induction Motor minimum 110kW as per IE3</p> <p>2. The Applicant should have supplied 415 V Squirrel Cage Induction Motor minimum 110kW during last five years from the date of application.</p> <p>3. The applicant should have in house testing facilities including measurement of efficiency of motor as per IS/IEC 60034-30</p>		
C)	<p>Other Documents to be submitted: In addition to the documents required in support of meeting technical requirements as stated above, following documents are required to be submitted by the Applicants applying for enlistment:-</p> <p>1. Three POs of the highest executed values of similar work during previous five years from the date of application. Copy of Invoice / Completion certificate from the concerned buyer/s in support of successful execution of supply against the POs to be submitted.</p> <p>2. Audited balance sheet including Profit & Loss statement for the previous three completed financial years reckoned from the date of application. In case the audited documents are not ready / available, then certified copy by a registered practicing Chartered accountant may be submitted.</p> <p>3. Latest annual report OR NSIC / SSI / MSME registration certificate / BIS license / ISO certificate / Certificate of registration from the concerned excise department / any other statutory document as a proof of being manufacturer of the required material.</p> <p>4. Any other documents in addition to the above which the applicant wants to submit.</p>		
D)	NOTE-1	Similar works means: Manufacture and supply of LT motors of 100 KW or higher rating	
	NOTE-2	The executed value means Basic value of quantity of similar works executed/supplied against the reference PO(also applicable to partly executed POs as on date of application).Where PO value is composite(i.e. including Taxes etc.),the applicant to give item-wise break-up of Composite PO value mentioning Basic Value, Taxes etc.	

NTPC LTD
CC-OS
EOC NOIDA

Sub: Technical Specifications for Vendor Enlistment for supply of LT Motor (Above 100 KW)

A)	MEG DETAILS		
	1.0	MEG NO.	86MEC-01(C)
	2.0	MEG DESCRIPTION	LT Motor (Above 100 KW)
	3.0	RESPONSIBILITY CENTRE	WR-I
B)	Technical Specifications: 415/240 V +- 10% , 50 Hz+3% to -5%, and combined variation 10%, Squirrel Cage Induction Motor above 100 kW as per IE3 as per relevent IS/IEC 60034-30		