

NTPC LTD
CORPORATE OPERATION SERVICES, EOC, NOIDA
VENDOR ENLISTMENT FOR O&M WORKS PACKAGE ON PAN NTPC BASIS

1	CEG No.	EMD: 06
2	Brief description of CEG	Maintenance Contract for 220kV and 400kV Switchyard Equipments and EHV Transformers &, UT, UAT, UST, SST
3	Responsibility Centre	WRHQ-I
4	Brief scope of work	<ol style="list-style-type: none"> 1. Daily (cleaning and checking), monthly, quarterly and annual Preventive maintenance and related testing of Switchyard equipments like:- <ol style="list-style-type: none"> a) EHV & HV transformers like GT, UAT, UT, UST,SST etc. including the checking and maintenance of cooling fans and pumps. This includes oil replacement & filtration b) 400KV & 220 KV SF6 breakers c) Shunt reactors d) 33 KV & 11KV breakers (including support work for O/H of breakers) e) EHV & HV bus bars f) Lightning arrestors & Wave trap g) Isolators & Earthing switches (including dismantling and re-erection) h) Relay and control panels i) Earthing system checking and rectification for individual equipments as well as earthing pit & mat. 2. Routine breakdown maintenance of all above equipments. <p>Detailed scope of work would be as provided in the respective tender for works.</p>
5	Technical Qualifying requirements	<ol style="list-style-type: none"> 1. The Bidder should have valid Class A (HT) Electrical License. 2. The Bidder should have executed contracts for Erection & Commissioning or maintenance of Switchyard Equipments & Bays in a Power Station / Transmission System having Switchyard /Substation of 220kV or more during last five years under end-user or under 'PSU' or its Joint Venture Company / Govt. or Semi-Govt. department <p>Cable laying/ structural erection shall not be considered for the purpose of QR.</p>
	Document to be submitted by Vendor in support of meeting QR	<ol style="list-style-type: none"> 1) Relevant PO copy of successful execution of Erection & Commissioning or maintenance of Switchyard Equipments & Bays in a Power Station / Transmission System having Switchyard /Substation of 220kV or more during last five years under end-user or under 'PSU' or its Joint Venture Company / Govt. or Semi-Govt. department and Client's Completion Certificate/RA bill/Final Deviation Statement. 2) Valid Electrical contractor's License issued by any State Statutory Authority

NTPC LTD
CORPORATE OPERATION SERVICES, EOC, NOIDA
VENDOR ENLISTMENT FOR O&M WORKS PACKAGE ON PAN NTPC BASIS

CEG No.		EMD: 06
6	Additional Documents to be submitted	<p>In addition to the documents required in support of meeting technical requirements as stated above, following documents are required to be submitted by the Applicants applying for enlistment:-</p> <ol style="list-style-type: none"> 1. Three POs with BOQ of the highest executed values of similar work during previous five years from the date of application and Copy of Completion Certificate /RA Bill/ final deviation statement from the concerned client in support of successful execution of supply against each of the POs to be submitted. 2. Audited balance sheet including Profit & Loss statement for the previous three completed financial years reckoned from the date of application. In case the audited documents are not ready / available, then certified copy by a registered practicing Chartered accountant may be submitted. 3. NSIC / SSI / MSME/ESIC registration certificate (if applicable) 4. PF and Service Tax registration certificate 5. Any other documents in addition to the above which the applicant wants to submit.
7	Notes	<ol style="list-style-type: none"> 1. Similar work means: Erection & Commissioning or maintenance of Switchyard Equipments & Bays in a Power Station / Transmission System having Switchyard /Substation of 220kV during last five years under end-user or under 'PSU' or its Joint Venture Company / Govt. or Semi-Govt. department. Cable laying/ structural erection shall not be considered for the purpose of QR. 2. Value means basic value (excluding taxes) of the P.O. pertaining to executed similar work as mentioned vide Note-1 above. Where P.O. value is composite, the applicant should have to give break-up of Composite PO value mentioning Basic Value, taxes etc.